

# CVC Testing Technology (Shenzhen) Co., Ltd.

## Verification of Conformity

No. EN2026-01

Expiry date: Jun. 11, 2031

### About EN Standards

<i>Applicant:</i> <i>Add</i>	<b>Shenzhen Sinexcel Isuna Energy Technology Co., Ltd.</b> Room 301, Building 6, BaiWangXin High-tech Industrial Park, Nanshan District, Shenzhen City, China
<i>Product/Material:</i>	<b>Hybrid Inverter</b>
<i>Trade Mark:</i>	/
<i>Model/Type:</i>	Isuna L50K-TH-S
<i>Rated Specification:</i>	Max. PV Input Voltage: 1000Vd.c., MPPT Voltage Range: 150~850Vd.c., Max. PV Input Current: 4*40Ad.c., Isc PV: 4*60Ad.c. Rated AC Output Voltage: 380/400Va.c. Output Frequency: 50Hz/60Hz, Max. Output Current: 79.8Aa.c. Rated AC Output Power: 50kW, Max. Apparent power: 55kVA
<i>Test According to:</i>	EN 50530:2010+ A1:2013
<i>Referred to the Technical Report:</i>	GJWSZ2026-0352

*This certificate of compliance is based on an evaluation of a tested sample of the product mentioned above. It does not imply assessment of series-production of the product. The applicant should hold the whole technical report at the disposal of the competent authority.*



Date : Jun. 11, 2026